

TEST CERTIFICATE

Issued to: FAISAL JASSIM INDUSTRIES
P.O. Box 1871, DUBAI INVESTMENT PARK
DUBAI
UNITED ARAB EMIRATES

For the product: Low-voltage switchgear and controlgear assemblies

Trade name: FAISAL JASSIM

Type/Model: 1000 A Promaster Switchboard

Ratings: Ue 415 V, Ui 800 V, Uimp 8 kV, InA 1000 A, Icw 50 kA – 1.0 s, IP44

Manufactured by: FAISAL JASSIM INDUSTRIES
P.O. Box 1871, DUBAI INVESTMENT PARK
DUBAI
UNITED ARAB EMIRATES

Subject: Design verification; construction and performance

Requirements: IEC 61439-2, 1st ed. 2009-01
Clauses: 10.2.2, 10.2.3, 10.2.5, 10.2.7, 10.3, 10.4, 10.5, 10.6*, 10.7, 10.8, 10.9, 10.10, 10.11, 10.12 and 10.13.

Remarks: See the annex to this certificate for details
*The examination of the compliance of components in the assembly, with their relevant product standard, is not part of this project.


This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in report no. 2142311.02-INC, March 1, 2011

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA

Arnhem, March 1, 2011

Number: 2142311.101

DEKRA Certification B.V.



H.L. Schendstok
Certification Manager



certificate and adjoining reports is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.