

UL TYPE EXAMINATION CERTIFICATE

Certificate No. UL TEC-00050
Page 1/1
Date of Issue 2014-04-09

Applicant Faisal Jassim Industries L.L.C,
PO.BOX 113825, Dubai Investment Park,
Plot No.598-1152, Dubai, UAE.

Manufacturer Faisal Jassim Industries L.L.C,
PO.BOX 113825, Dubai Investment Park,
Plot No.598-1152, Dubai, UAE.

Product Sample Description Low Voltage Power Factor Correction Bank, incorporating a three-phase and neutral vertical bus bar system and protective bus bar.

Designation 450 KVAR PFC PROMASTER CAPACITOR BANK

Ratings Rated voltage (Un): 440V
Rated Reactive Power : 450KVAR
Rated frequency: 50 Hz
IP rating : IP 31

Product Sample Tested and found in compliance with Standard(s) IEC 61921(ed.1), in accordance with IEC 61439-1(ed.2)

Test Report Nos. 4786195564.1.1 issued on 2014-04-09

Additional information N/A

Certification Manager
Jan-Erik Storgaard

Certification Body

This is to certify that the sample(s) of the Product described herein has been investigated to and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The Applicant/Manufacturer are solely and fully responsible for conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**UL International Demko A/S, Borupvang 5A,
2750 Ballerup, Denmark, Tel. +45 44 85 65 65
info.dk@ul.com, www.ul.com**



UL TYPE EXAMINATION CERTIFICATE

Certificate No.	UL TEC-00052
Page	1/1
Date of Issue	2014-04-14
Applicant	Faisal Jassim Industries L.L.C, PO.BOX 113825, Dubai Investment Park, Plot No.598-1152, Dubai, UAE.
Manufacturer	Faisal Jassim Industries L.L.C, PO.BOX 113825, Dubai Investment Park, Plot No.598-1152, Dubai, UAE.
Product Sample Description	Low Voltage Power Factor Correction Bank, incorporating a three-phase and neutral vertical bus bar system and protective bus bar.
Designation	175 KVAR PFC PROMASTER CAPACITOR BANK
Ratings	Rated voltage (Un): 440V Rated Reactive Power : 175kVAR Rated frequency: 50 Hz IP rating : IP 31
Product Sample Tested and found in compliance with Standard(s)	IEC 61921(ed.1), in accordance with IEC 61439-1(ed.2)
Test Report Nos.	4786195514.1.1 issued on 2014-04-10
Additional information	N/A

Certification Manager
Jan-Erik Storgaard

Certification Body

This is to certify that the sample(s) of the Product described herein has been investigated to and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The Applicant/Manufacturer are solely and fully responsible for conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**UL International Demko A/S, Borupvang 5A,
2750 Ballerup, Denmark, Tel. +45 44 85 65 65
info.dk@ul.com, www.ul.com**



UL TYPE EXAMINATION CERTIFICATE

Certificate No. UL TEC-00042
Page 1/1
Date of Issue 2014-03-25

Applicant Faisal Jassim Industries L.L.C,
PO.BOX 113825, Dubai Investment Park,
Plot No.598-1152, Dubai, UAE.

Manufacturer Faisal Jassim Industries L.L.C,
PO.BOX 113825, Dubai Investment Park,
Plot No.598-1152, Dubai, UAE.

Product Sample Description Low Voltage Power Factor Correction Bank, incorporating a three-phase and neutral vertical bus bar system and protective bus bar.

Designation 75 KVAR PFC PROMASTER CAPACITOR BANK

Ratings Rated voltage (Un): 440V
Rated Reactive Power : 75kVAR
Rated frequency: 50 Hz
IP rating : IP 31

Product Sample Tested and found in compliance with Standard(s) IEC 61921(ed.1), in accordance with IEC 61439-1(ed.2)

Test Report Nos. 13CA50195 issued on 2014-03-24

Additional information N/A

Certification Manager
Jan-Erik Storgaard

Certification Body

This is to certify that the sample(s) of the Product described herein has been investigated to and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The Applicant/Manufacturer are solely and fully responsible for conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**UL International Demko A/S, Borupvang 5A,
2750 Ballerup, Denmark, Tel. +45 44 85 65 65
info.dk@ul.com, www.ul.com**



UL TYPE EXAMINATION CERTIFICATE

Certificate No. UL TEC-00043
Page 1/1
Date of Issue 2014-03-25

Applicant Faisal Jassim Industries L.L.C,
PO.BOX 113825, Dubai Investment Park,
Plot No.598-1152, Dubai, UAE.

Manufacturer Faisal Jassim Industries L.L.C,
PO.BOX 113825, Dubai Investment Park,
Plot No.598-1152, Dubai, UAE.

Product Sample Description Low Voltage Power Factor Correction Bank, incorporating a three-phase and neutral vertical bus bar system and protective bus bar.

Designation 25 KVAR PFC PROMASTER CAPACITOR BANK

Ratings Rated voltage (Un): 440V
Rated Reactive Power : 25kVAR
Rated frequency: 50 Hz
IP rating : IP 31

Product Sample Tested and found in compliance with Standard(s) IEC 61921(ed.1), in accordance with IEC 61439-1(ed.2)

Test Report Nos. 13CA50196 issued on 2013-03-24

Additional information N/A

Certification Manager
Jan-Erik Storgaard

Certification Body

This is to certify that the sample(s) of the Product described herein has been investigated to and found to have been in compliance with the Standard(s) indicated on this Certificate, in accordance with the UL Type Examination Certificate Program Requirements. This certificate and test results obtained apply only to the product sample(s) submitted by the Applicant. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured products. UL has not established Follow-Up Service or other surveillance of the product. The Applicant/Manufacturer are solely and fully responsible for conformity of all products to all applicable Standard(s), specifications or requirements. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

**UL International Demko A/S, Borupvang 5A,
2750 Ballerup, Denmark, Tel. +45 44 85 65 65
info.dk@ul.com, www.ul.com**

